

PFAS Sampling Results Summary											
PFAS (6) Results in ppt											
Sample Sites	Finished				Finished		Finished				
	OMR WTP	Well 1	Well 1A	Well 3	Green Meadow WTP Well 4	Well 4	Rockland Ave WTP	Rock Well 2 (05G)	Rock Well 3 (06G)	Rock Well 5 (07G)	
Voluntary monitoring											
8/5/19	5.7	5.4		4.1	9.4	5.6					
8/19/19	5.6	5.1	5.8								
11/24/20	14.9	12.5			10.7		3.7	3.1	11.9	2.3	
1/5/21						11.7					
2/1/21											
3/1/21											
* Required by MassDEP											
4/1/21	15.99						4.76				
4/27/21					12.17						
5/12/21					9.3						
5/24/21	15.03										
6/1/21	15.34				12.42						
7/1/21	16.84				8.56		4.32				
8/1/21	17.58				11.09						
9/1/21	17				12.5						
10/1/21	16.5				9.22		4.65				
11/9/21	17.1				13.5						
12/1/21	16.8				6.76						
1/1/22	11.1				3.83		3.44				
Notes											
	MassDEP Maximum Contaminant Limit (MCL) for PFAS (6) is 20 ppt										
	Well 4 and OMR Monthly and Rockland Quarterly										
	* April 1, 2021 MassDEP requires compliance monitoring for water systems serving between 10,000 and 50,000 people										